

# GREASE INTERCEPTOR CERTIFICATE

## PERFORMANCE LEAKAGE TEST

### PER (ASTM C 1227)

**SITE NAME:** \_\_\_\_\_

**SITE ADDRESS:** \_\_\_\_\_

\*Per ASTM C 1227, performance leakage testing is performed using vacuum testing or water-pressure testing.

Mark which performance leakage test was conducted in the below table:

TEST PERFORMED	TEST TYPE	METHOD	PASS
<input type="checkbox"/>	Vacuum Test	Seal the empty tank and apply vacuum to 2 in. (50 mm) of mercury. The tank is approved if 90% of vacuum is held for two minutes.	<input type="checkbox"/>
<input type="checkbox"/>	Water-Pressure Test	Seal the tank, fill with water, and let stand for 24 hours. Refill the tank. The tank is approved if water level is held for one hour.	<input type="checkbox"/>

This is to certify that the \_\_\_\_\_ gallon Grease Interceptor, Manufactured by \_\_\_\_\_, Model No. \_\_\_\_\_ installed at the above referenced address has passed a performance leakage test conducted in accordance with ASTM C 1227 as outlined in the above table.

**DATE:** \_\_\_\_\_

**SIGNATURE SITE REP/CONTRACTOR:** \_\_\_\_\_