

Electric Service for Mobile Home Parks, RV Sites, and Camping Sites

(Applies to other installations with multiple meters within close proximity to each other)

1. All new delivery points shall be coordinated between CUB Engineering Department and the property owner and/or property manager and NOT through a tenant. Failure to coordinate the location of new delivery points with CUB Engineering Department may result in a delay of service to the delivery point.
2. Delivery points shall consist of ganged meter structures (grouped meter centers) and be planned and situated in locations that will accommodate future tenants furthest from the delivery point. For example: (1) 6-gang with one riser or (2) 6-gang back-to-back with (2) risers ((2) riser maximum per delivery point). **Failure to plan ahead may result in a burden on the Property Owner, requiring the existing meter center to be moved to a more centrally located point.**
3. Existing delivery points with only 1 or 2 meter centers that are located within close proximity to each other as well as a newly requested delivery points, shall be grouped together to make one (1) delivery point as described in Note #2 above.
4. Customer delivery points shall be located outside of CUB's existing easements; 10' from the centerline of CUB's 1-phase and 15' from the centerline of CUB's 3-phase OH or UG facilities.
5. Electric service can be set in the tenant's name provided the meter center structure is installed, operated, and maintained by the property owner.
6. All electrical work and application for permits must be performed by a TN State Licensed Electrician. If the work alters the structure of the electrical system, this may necessitate the work to be approved and stamped by a Registered Licensed Professional recognized by the Tennessee Board of Architectural and Engineering Examiners.
7. All electric delivery points must serve only what is specified on the electrical permit and what is described in the electrical inspection passed by the TN State Electrical Inspector. At CUB's sole discretion, violations may result in electric service to the delivery point being disconnected until remedial action is taken.